

Kitemark™ Certificate

This is to certify that:

UAB Merseta
K. Dulksnio g
Narsieciai
Kaunas
LT-53304
Lithuania

Holds Certificate Number:

KM 722910


In respect of:

BS 6165

Specification for small disposable fire extinguishers of the aerosol type.

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2023-05-24

Latest Issue: 2023-05-24

Effective Date: 2023-05-24

Expiry Date: 2026-05-23

Page: 1 of 2

Kitemark™ Certificate

No. KM 722910

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review Report
ReinoldMax StopFire 500	500 g 2% (m/m) TOWALEX AFFF 1% PLUS small single use stored pressure extinguisher. Working pressure: 10 bar Fire rating: 3A; 13B; 5F;	RM500, Latest 14/04/2020 revision	3123738

All the above products are certified to BS 6165:2019+A1:2022

First Issued: 2023-05-24

Latest Issue: 2023-05-24

Effective Date: 2023-05-24

Expiry Date: 2026-05-23

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.